

Public Service Company of New Mexico

Open Transmission Planning Meeting

November 3, 2016

Albuquerque, NM



INTRODUCTION

- **Public Stakeholder Meeting**
 - **Order 890 Objective to improve transparency and stakeholder involvement.**
 - **Planning Process Defined in Attachment K of OATT**
- **March Meeting Reviewed**
 - **Planning Process**
 - **Coordination with WECC (PCC & TEPPC), WestConnect**
 - **PNM 10-Year Plan Study Scope**
- **November Meeting**
 - **Review 10-Year Plan Results**
 - **Input to Next Planning Cycle**
 - **Certain Other Business**



10-YEAR TRANSMISSION PLAN



PNM Open Transmission Planning Meeting
November 3, 2016 Albuquerque, NM

Overview of TPL-001-WECC-CRT-3

Conditions	Steady State			
	Voltage (per unit)		Voltage Drop	
	Previous	New	Previous	New
Normal ALIS (P0)	0.95-1.05	0.95-1.05 ¹	Not Applicable	
	0.95-1.1			
Single Contingency (P1)	0.925-1.08	0.9-1.1	6 %	8 %
	0.95-1.1		6 %	
	0.925-1.08		7 %	
	0.90 – 1.08		6 %	
	0.90 – 1.08		7 %	
Multiple Contingency (P2-P7)	0.90-1.087	0.9-1.1	10 %	None Specified
	0.95-1.1			

Conditions	Transient Voltage Response	
	Previous	WECC
Single Contingency (P1)	Dip > 25% of pre-fault voltage Dip > 20% of pre-fault voltage for more than 20 cycles	Following fault clearing, recover to 80% of pre-fault voltage within 20 seconds of the initiating event for each applicable BES bus serving load
		Following voltage recovery above 80%, voltage at applicable BES bus serving load shall not dip below 70% of pre-contingency for more than 30 cycles or remain below 80% of pre-contingency for more than two seconds for P1-P7
		For Contingencies without a fault (P2.1), voltage dips at applicable BES bus serving load shall not dip below 70% of pre-contingency for more than 30 cycles or remain below 80% of pre-contingency for more than two seconds
		Oscillations that do not show positive damping within 30 seconds after the start of the studied event shall be deemed unstable.



10-YEAR TRANSMISSION PLAN

- **OBJECTIVES OF STUDY EFFORT:**
 - **Support Data Base Development for PNM and Regional Studies**
 - 2018 (1-yr), 2021 (5-yr) , 2026 (10-yr)
 - **Maintain Reliability**
 - **Define Transmission for Native, Network and Point-Point Customers**
 - **Incorporate Plans Developed Through FERC Processes, NM IRP and Regional Planning Analysis**



STUDY SCOPE

- Review transmission adequacy with retail and network customer updates to designated network resources and load.
- Determine if system mitigations are needed to serve expected obligations (load forecasts and expected firm transfers) during the 10 year planning horizon without violating WECC/NERC reliability standards.
- Develop operational mitigations or system improvements to maintain system reliability and associated cost estimates and schedule.
- Incorporate assessments of economic congestion to the extent a need is identified by PNM's or other's involvement in the WECC/TEPPC process for providing this type of assessment.



PROJECT DRIVERS

- **Compliance with Reliability Standards**
- **Provide Service to New Load Locations**
- **Interconnection Projects**
- **Recommendations for projects requiring joint study or solutions**




Project Overview




PNM Open Transmission Planning Meeting
November 3, 2016 Albuquerque, NM

Northern New Mexico Projects



PNM Open Transmission Planning Meeting
November 3, 2016 Albuquerque, NM

Southern New Mexico Projects



➤ Southern New Mexico

➤ Alamogordo Replacement Capacitor Installation (ISD 2017)
 ➤ Alamogordo Voltage support Phase 2 (ISD 2019+)

Completed Project ———
 Planned Project ———

Generation	Transmission	Stations
Ownership	PNM	PNM
PNM*	46 kV	Substation
Capacity	115 kV	Switching Station
Non Utility-Scale	230 kV	Other Utilities
Utility-Scale**	345 kV	Substation
Fuel	Other Utilities	
Natural Gas	115 kV	
Solar	345 kV	



COMPLETED RELIABILITY PROJECTS

- Rio Puerco Station Expansion and SVC




RELIABILITY PROJECTS UNDER CONSTRUCTION




PNM Open Transmission Planning Meeting
November 3, 2016 Albuquerque, NM

RICHMOND SWITCHING STATION

Metro Albuquerque




Detailed Area (Project lines highlighted in yellow)





RICHMOND SWITCHING STATION

- **In Service Date – 2017**
- **Purpose**
 - Mitigate Albuquerque 115 kV overloads.
 - Provide additional source and voltage support for the Sandia Switching station.
- **Project Includes:**
 - A new 115 kV three breaker ring bus switching station on the existing line between Sandia and North
 - Closing a normally open switch between North and Sandia.

RICHMOND SWITCHING STATION




2nd YAH-TA-HEY TRANSFORMER



2nd YAH-TA-HEY TRANSFORMER

- In Service Date – 2017
- Purpose – Mitigate overloads of existing transformer and improve Yah-Ta-Hey contingency voltage performance
- Project Includes:
 - Expanding the McKinley 345 kV and Yah-Ta-Hey 115 kV stations
 - Expanding and upgrading Yah-Ta-Hey 115 kV station
 - Installation of a second transformer

2nd YAH-TA-HEY TRANSFORMER




PLANNED RELIABILITY PROJECTS




PNM Open Transmission Planning Meeting
November 3, 2016 Albuquerque, NM

ALAMOGORDO PROJECTS



ALAMOGORDO VOLTAGE SUPPORT PHASE 2

- In-Service Date: 2019+
- Purpose – Provide adequate voltage support and operational flexibility by increasing the transmission load serving capability.
- Project includes
 - Installation of an additional switchable shunt capacitor



OTHER PROJECTS



PNM Open Transmission Planning Meeting
November 3, 2016 Albuquerque, NM

OPERATOR OR RAS SOLUTIONS

- **Only Local Area Impacts**
- **Certain N-2 overloads addressed by RAS or Operator action.**
 - **Generation Re-dispatch**
 - **Load Shedding**
 - **Capacitor switching**
 - **Transformer Tap Adjustments**

10-YEAR PLAN QUESTIONS?

**Ten-Year Plan Report Available for Stakeholders completing
CEII Request**



PNM Open Transmission Planning Meeting
November 3, 2016 Albuquerque, NM

2017 STUDY PLAN INPUT

- **March Meeting to Review 10-Year Plan Scope**
- **2017 TEPPC study request window typically closes January 31.**
- **Discussion**

Large Generator Interconnection Cluster Activity

- **Fifth Definitive Cluster closed November 13th, 2014**
 - One project is in LGIA negotiations
 - One project is in Facilities Study Process
- **Six Definitive Cluster closed August 10th, 2015**
 - three requests of 158 MW are in study mode.
- **Seventh Definitive Cluster closed May 6th, 2016**
 - One request of 400 MW are in study mode.

Next Cluster Window


- **Definitive Interconnection Cluster Window opens November 3rd, 2016 and closes January 31st, 2017**
- **Preliminary Interconnection Cluster Window opened March 5th, 2017 and closes June 6, 2017**



Interconnection and Transmission Service Related Projects

- **Generator Interconnection**
 - El Cabo Wind Farm interconnection at Clines Corners.
- **Wire-Wire Interconnections**
 - Cabezon Switching Station
 - Blackwater Expansion for Western Interconnect Tie
- **Transmission Service Projects**
 - Guadalupe SVC

El Cabo Wind Farm




PNM Open Transmission Planning Meeting
November 3, 2016 Albuquerque, NM

Cabezon Switching Station

- 33 miles north of Rio Puerco on the San Juan – Rio Puerco 345 kV transmission line.
- A 3 breaker ring that provides a new delivery point Tristate G & T under the Network Transmission Service Agreement.
- Tristate will provide a 345 to 115 kV transformer which ties into the Algodones – La Jara 115 kV line segment.
- In-service fourth quarter of 2017


Wires to Wires Interconnections



Blackwater 345 kV Switchyard Expansion

- Expand to a 3 breaker ring bus configuration to accommodate an interconnection to Western Interconnect line.
- Western Interconnect line will interconnect Broadview and planned Grady wind generation facilities.
- In-service date December 2016 (Broadview)

Blackwater 345 kV Switchyard Expansion




PNM Open Transmission Planning Meeting
November 3, 2016 Albuquerque, NM

Guadalupe SVC

- **Size: -100 to +250 MVAR**
- **Voltage support for transmission service provided to Pattern and Avangrid.**
- **Guadalupe Switching Station expanded to four terminations to accommodate SVC.**
- **2018 in-service date.**

Guadalupe SVC



REGIONAL ACTIVITIES

- [SunZia](#)
 - Permitting activities Ongoing
 - Commercial operation date in 2021
 - Completed selection of its anchor customer in August 2016
- [Tres Amigas](#)
 - [Tres Amigas LLC](#) and [Pattern Energy Group LP](#) formed Western Interconnect LLC to develop, finance, construct, own and operate line that will interconnect Broadview and Grady.
 - Interconnection at Blackwater December 2016
- [Lucky Corridor](#)
 - Project modified to single 345 kV line from Gladstone area to Ojo switching station
 - Completed WECC Project Coordination Review Group report
- [Mora Line Project](#)
 - Lucky Corridor's Mora Line project is designed to carry 180 MW at 115 kV.
 - 102 miles
 - Working on interconnection studies with PNM and Tri-State



REGIONAL ACTIVITIES

- **Southline Project**
 - WECC Rating Process Completed March 23, 2015
 - Final EIS Issued
 - Construction expected to begin in 2017
 - In Service Date: In phase between 2018 and 2020
- **Centennial West Clean Line Project**
 - Development agreement with Western Area Power Administration
 - See project website for latest developments.
- **Western Spirit Clean Line Project**
 - Approximately 1500 MW 345 kV Project to increase access from Central New Mexico to the Four Corners hub.
 - Currently performing System Impact Study for interconnection to PNM's system at the Rio Puerco Switching Station.



REGIONAL ACTIVITIES


- Verde Project
 - Interconnects to PNM's Ojo and Norton 345 kV stations
 - PNM is currently performing a System Impact Study
 - 2016-2017 Permitting, Public Engagement, ROW, Engineering
 - 2018-2019 Construction, In Service Date 2020



Map of Regional Transmission Projects

-  Broadview/Grady 345 kV
-  Centennial West 500 kV DC
-  Centennial West Alt. 500 kV DC
-  El Cabo 345 kV
-  Lucky Corridor 345 kV
-  Mora Line 115 kV
-  Southline 345 kV
-  Sun Zia 500 kV
-  Verde 345 kV
-  Western Spirit 345 kV
-  Stations

RFM 1349 January 12, 2016



ORDER 1000 UPDATE

- Adds planning process for identifying regional projects that are more cost effective and efficient than projects in local plans.
- Establishes cost allocation methodology for regional projects.
- Full Biennial Cycle 2016-2017
- Current Activities:
 - Approved 2016-2017 Base models for Regional Analysis – October 2016
 - Scenario Cases still under development
 - Planning Subcommittee and Cost Allocation Subcommittee meeting bi-weekly
 - Planning Management Subcommittee meeting monthly.



NEXT MEETING

March 9, 2017

PNM Open Transmission Planning Meeting
November 3, 2016 Albuquerque, NM



QUESTIONS OR COMMENTS?

Tom Duane

thomas.duane@pnm.com

